

UPDATING THE OMNITOUCH 5.7e

The USB Update Port on the OmniTouch 5.7e allows you to update the touchscreen to the latest firmware and the HAI default design. This allows you to update the OmniTouch 5.7e when HAI Automation Studio is not available or is unable to connect.

When updating using the USB Update Port:

1. If a custom design is loaded in the OmniTouch 5.7e, the custom design will be overwritten with the HAI default design.
2. All custom settings (Network, Controller, Screen Setup, and Cameras) will be reset to factory default. You will need to manually reenter all of these settings after updating.

The Update Port is a USB port in the lower right section of the touchscreen.



To update the OmniTouch 5.7e Touchscreen:

- 1) Load the two update files on a USB thumb drive (the file entitled “Version_V3_Updater.57z” is required to update the touchscreen to Version 3 firmware).
- 2) Plug the thumb drive into the USB Update Port on the OmniTouch 5.7e Touchscreen and press the reset button.
- 3) When the USB drive reboots, the touchscreen will read the files on the root directory of the drive and display any applicable update files.
 - a. It may take several seconds before the files are displayed on the touchscreen.
 - b. Even though there are 2 files on the USB drive, only the file with the version number will be displayed in the list (i.e. the file entitled “Version_V3_Updater.57z” will not be displayed).
- 4) Select the desired file from the list and then press the “Next” button. Follow the instructions on the screen.